

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1496:107 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Models FAS-1215, -2415, -1230, -2430, -121575, -241575, -2475 and -24110 audible strobes followed by any three alpha/numeric characters indicating lens orientation, lettering and color.

Model FAH-12, -24 audible appliances (no strobe), followed by an alpha or numeric character indicating product color.

RATING: Electrical FAS-12: 10.5-15.6 VDC/Vrms; FAS-24: 20-31 VDC (18-31Vrms); FAH-12: 9-15.6 VDC/Vrms; FAH-24: 18-31 VDC/Vrms

Candela 15= 15cd, 1575= 15/75cd, 30= 30cd, 75= 75cd, 10= 110cd

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances. All models are for wall mount only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as audible and audible/visual signaling devices suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only except Models FAH-12 and FAH-24 audible appliances are suitable for indoor/outdoor

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Models FAH-12 and FAH-24 audible devices are not suitable for the hearing impaired application since they do not employ strobe light.

XLf: 7125-0785:131

12-22-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager